

This Directorate General has issued approval to the electrical flameproof- cum – weatherproof electrical equipment as per the following details during the period 01.07.2010 to 31.12.2010

Sl.No	Name of the Company	Particulars of Equipment	Approval and date	Validity	Remarks
1.	M/s. Emco Dynatorq Pvt. Ltd, 1003, GIDC, Waghodia, Vadodara - 391760 Gujarat.	Flameproof cum weatherproof enclosure for fail-safe brake for use in Gas Group IIA & IIB for Zone 1&2 area only, (i) Type : 14.458, Size: 10 designated by Cat.: No. 458.0 (ii) Type : 14.458, Size: 16 designated by Cat.: No. 458.0 (iii) Type : 14.458, Size: 25 designated by Cat.: No. 458.0 (iv) Type : 5000, Size: 5140 designated by Cat.: No. 5000	No: 66/2/2010- Tech dated 8 th July 2010	Valid for a period of 5 years up to 7th July 2015	Revalidation due in 2015
2.	M/s HEM Industries. Survey No.738/1, Somnath Road, Dabhel, Daman- 396210	Approval of Flameproof cum Weather proof Three Phase Foot Mounted Squirrel Cage Induction Motor, with terminal box, frame sizes 71, 90, 100, 225M, 250M, and 280 in cast iron construction, for use in Gas Group IIA & IIB atmospheres only.	No.66/01/2009-Tech dated 22nd September, 2010	Valid for a period of 5 years up to 21st September, 2015	Revalidation due in 2015
3.	M/s HEM Industries. Survey No.738/1, Somnath Road, Dabhel, Daman- 396210	Revalidation of Approval of Flameproof cum Weather proof Three Phase Foot Mounted Squirrel Cage Induction Motor, with terminal box, frame sizes 63, 80, 112, 132, 160L, 180L and 200L, for use in Gas Group IIA & IIB atmospheres only.	No.66/01/2009-Tech dated 22nd September, 2010	Valid for a period of 5 years up to 21st September, 2015	Revalidation due in 2015
4.	M/s Jaibalaji Control Gears Pvt.Ltd., 89, (New: 107), SIDCO Industrial Estate, Post Box No.27 Ambatur Chennai-	Flameproof cum weather proof enclosure of EPHA- 1 Limit Switch for use in Zone 1&2 Gas Group IIA, IIB & IIC atmospheres	No.66/3/2010-Tech Dated 16 th November, 2010	Valid for a period of 5 years up to 15 th July 2015	Revalidation due in 2015

	600098				
5	M/s. Honeywell Automation India Limited, 53, 54, 56 &57, Hadapsar, Industrial Estate, Pune – 411013 Maharashtra	Approval to Flameproof enclosure of (i) Model No. ST 3000, R300 series 100/900, pressure transmitter and (ii) Model No. STT 3000 temperature transmitter using in Gas Group IIA, IIB & IIC atmospheres.	No: 66/4/2010- Tech dated 14 th December, 2010	Valid for a period of 5 years up to 13 th December, 2010	Revalidat ion due in 2015